

QUINTIN CERTIFICATIONS
825 route de Romans
38160 SAINT ANTOINE
L'ABBAYE - France
Tél. +33.(0)7 66 29 39 28
g.quintin.consult@gmail.com
www.quintincertifications.com

CERTIFICATE OF CONFORMITY N°RQC2021-006/A

1. APPLICANT

Applicant: Mr Rémy TIMMERMANS
Manufacturer: FALLPROTEC SA - 43-45 ZA Op Zaemer 4959 – Bascharage - Luxembourg

2. EQUIPMENT

Type of equipment: **Anchor device type A – EN 795 : 2012* and TS 16415 :2013***
Trademark: **FALLPROTEC SA**
Reference: **DAVIT ARM DAV 006**

3. DESCRIPTION

Davit arm composed of :

- A vertical post Ø110x20 mm length 2000 mm in Aluminum
- An arm 160X60x4 mm length 1620 mm in Aluminum with a mobile anchor in aluminum included 2 ring anchors M12 in stainless steel which permit the cantilever from 1110 to 1560 mm
- A bracket in stainless steel height 260 or 510 mm

The anchor device is intended to be use in horizontal surface by two people at the same time, one person is connected by ring.

(full description and results in the conformity report n°RQC2021-006-1).



4. TECHNICAL REFERENTIAL

The anchor device type A has been evaluated according to the relevant requirement of the standard EN 795 : 2012* "Personal fall protection equipment – Anchor devices" and the technical specification TS 16415 :2013* "Personal fall protection equipment – Anchor devices – Recommendations for anchor devices for use by more than one person simultaneously".

The anchor device has also been evaluated according to standard BS 8610:2017 type A1, A2, A3 and A5 under report n° RQC2021-005-1.

5. CONDITION OF USE

This anchor device type A is not considered as personal protective equipment against falls from a height. It is intended to be used, in combination with other components, as personal protective equipment against falls from a height.

6. CONCLUSION

The Anchor device Type A, reference **DAVIT ARM DAV 006**, presented by **FALLPROTEC SA** and described in the conformity report RQC2021-006-1, conforms to the requirements of European standard EN 795:2012* and Technical Specification TS 16415:2013* for using by 2 people simultaneously.

12/07/2021

The head of QUINTIN CERTIFICATIONS
Guillaume QUINTIN



QUINTIN
Validation électronique

Only the tests described in the harmonised standard marked with asterisk are performed under COFRAC accreditation, the instruction for use and marking are not covered by COFRAC accreditation. QUINTIN CERTIFICATIONS does not allow partial reproduction of this document and reproduction of the COFRAC logo. The full reproduction of this document is the only one allowed.

Cette attestation d'une page ne constitue pas le justificatif prévu par le code de la consommation (article L-115-27) par lequel un organisme distinct du fabricant atteste à des fins commerciales qu'un produit est conforme à des caractéristiques dans un référentiel déposé auprès de l'autorité administrative

QUINTIN CERTIFICATIONS – 825 route de Romans – 38160 SAINT ANTOINE L'ABBAYE – France TEL +33 (0) 7 66 29 39 28 – Email : g.quintin.consult@gmail.com
SARL au capital de 10 000 € - SREN 848 919 676 - TVA intracommunautaire FR818919676

QC-151-V3- Attestation de conformité Cofrac GB/RQC2021-006 A_FALLPROTEC.docx/ 12/07/2021 14:38